



Wayne-Westland Community Schools  
 Drinking Water Analysis  
 Project Number: AE170005

Franklin Middle School							
Date of Sampling: March 15, 2017							
Sampler: Jessica Perfetti							
Sample #	Location	Type <sup>1</sup>	Time Collected	EPA Action Level (ug/L) <sup>2</sup>	Results (ug/L)	Aerator Present Y/N	Notes
F-01	Kitchen, 2-compartment sink, left of storage room	KS	6:01 AM	15	13	N	First Draw
F-02	Right of Room 401, left bubbler	B	6:08 AM	15	1	N	First Draw
F-03	Right of Room 401, right bubbler	B	6:08 AM	15	ND <sup>3</sup>	N	First Draw
F-04	Across from Room 34, bubbler	B	6:15 AM	15	4	N	First Draw
F-05	Right of Room 301, left bubbler	B	6:21 AM	15	ND	N	First Draw
F-06	Right of Room 301, right bubbler	B	6:21 AM	15	ND	N	First Draw
F-07	Left of Room 10, bubbler	B	6:31 AM	15	4	N	First Draw
F-08	Room 14 (Band Room), bubbler	B	6:35 AM	15	6	N	First Draw
F-09	Right of Room 101, left bubbler	B	6:41 AM	15	ND	N	First Draw
F-10	Right of Room 101, right bubbler	B	6:41 AM	15	2	N	First Draw
F-11	Right of Room 201, left bubbler	B	6:47 AM	15	2	N	First Draw
F-12	Right of Room 201, right bubbler	B	6:47 AM	15	2	N	First Draw
F-13	Left of Mail Room, across from Room 501, right bubbler	B	6:53 AM	15	1	N	First Draw
F-14	Gym 603, bubbler closest to main entrance	B	7:01 AM	15	ND	N	First Draw
F-15	Gym 603, bubbler to right of girls locker room	B	7:04 AM	15	ND	N	First Draw

1) Type: B = Bubbler, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, AS = Nurse Sink, S = Sink Used for Drinking  
 2) <http://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non-Detect at Report Detection Limit of 1 ug/L