



Wayne-Westland Community Schools
 Drinking Water Analysis
 Project Number: AE160005

Graham Elementary School						
Date of Sampling: October 11, 2016						
Sampler: Brad Ziegler						
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Notes
G-01	Kitchen Prep Sink	KS	6:06 AM	15	4	First Draw
G-02	Room 120	CF	6:10 AM	15	ND ³	First Draw
G-03	Room 115	B	6:14 AM	15	2	First Draw
G-04	Room 113	B	6:18 AM	15	1	First Draw
G-05	Room 111	CF	6:24 AM	15	1	First Draw
G-06	Room 108	B	6:28 AM	15	4	First Draw
G-07	Room 107/Bathroom	B	6:31 AM	15	3	First Draw
G-08	Room 101	B	6:36 AM	15	1	First Draw
G-09	Main entry	B	6:40 AM	15	ND	First Draw
G-10	Audio Arts	CF	6:47 AM	15	160	First Draw
G-11	Receiving Hallway	B	6:50 AM	15	ND	First Draw
G-12	Clinic	CF	6:54 AM	15	4	First Draw
G-13	Office Testing Room	CF	6:58 AM	15	34	First Draw
G-14	Staff Lounge Room 102	CF	7:02 AM	15	1	First Draw
G-15	Room 105	CF	7:06 AM	15	1	First Draw

1) Type: B = Bubblers, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/to-be-regulated-drinking-water-contaminants>
 3) http://www.in.gov/idem/files/lead_epo_lead_copper_guide.pdf
 4) ND= Non Detected at Reported Detection Limit of 1 ug/L
 5) NT = Not Tested