



Wayne-Westland Community Schools  
 Drinking Water Analysis  
 Project Number: AE170005

John Glenn High School							
Date of Sampling: March 16, 2017							
Sampler: Jessica Perfetti							
Sample #	Location	Type <sup>1</sup>	Time Collected	EPA Action Level (ug/L) <sup>2</sup>	Results (ug/L)	Aerator Present Y/N	Notes
JG-01	Kitchen, 2-compartment sink, located in center island, across from pantry.	KS	6:04 AM	15	ND <sup>3</sup>	N	First Draw-used for food prep
JG-02	Cafeteria, southeast wall, under handicap sign.	BT	6:09 AM	15	ND	N	First Draw
JG-03	Cafeteria, southeast wall, under handicap sign.	WC	6:09 AM	15	ND	N	First Draw
JG-04	Across from J 159, between women's restroom and storage room.	B	6:17 AM	15	2	N	First Draw
JG-05	J160, in girls locker room, outside restroom.	B	6:21 AM	15	5	N	First Draw
JG-06	J163, in boys locker room, outside office.	B	6:27 AM	15	4	N	First Draw
JG-07	Between J & H hall, to the right of K-6 storage	B	6:33 AM	15	ND	N	First Draw
JG-08	2nd floor, between A and F hall, left of 228, right bubbler.	B	6:39 AM	15	2	N	First Draw
JG-09	2nd floor, between A and F hall, left of 228, left bubbler.	B	6:39 AM	15	ND	N	First Draw
JG-10	Between A and D hall, left of room A109	B	6:46 AM	15	1	N	First Draw
JG-11	Left bubbler, right of C184	B	6:55 AM	15	ND	N	First Draw
JG-12	Right bubbler, left of room 133, between H and E hall	B	7:00 AM	15	3	N	First Draw
JG-13	Left bubbler, left of room 133, between H and E hall	B	7:00 AM	15	ND	N	First Draw
JG-14	Right bubbler, between A and F hall, left of 145	B	7:08 AM	15	3	N	First Draw
JG-15	Left bubbler, between A and F hall, left of 145	B	7:08 AM	15	1	N	First Draw

1) Type: B = Bubbler, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink, SA = Sink Used for Drinking  
 2) <http://www.epa.gov/yourdrinkingwater/regulated-drinking-water-contaminants>  
 3) ND = Non-Detect at Report Detection Limit of 1 ug/L